

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1335:105 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Altronix, 140 - 58th Street, Building A-3W, Brooklyn, NY 11220
Contract: Alan Forman (718) 567-8181 Fax (718) 567-9056

DESIGN: Model MOM5 and MOM5C multi-output power module. Unit is designed for use with listee's Model AL400ULM power supply (CSFM Listing No. 7315-1335:100) or Model AL600ULM power supply (CSFM Listing No. 7315-1335:104) to provide five outputs for door holders, door strikes or similar devices. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an accessory for use with listee's separately listed model AL400ULM power supply.

02-07-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager